NET **NATIONAL ENVIRONMENTAL TESTING, INC.** ®

JUL 1 3 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250

Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

07/02/1998

NET Job Number: 98.04205
Page 1 of 3

Enclosed are the Analytical Results for the following samples submitted to NET, Inc. Indianapolis Division for analysis:

Project Description: TWICE WEEKLY WASTEWATER

Sample Number	Sample Description	Date Taken	Date Received
210906	OUTFALL 001	06/23/1998	06/23/1998

National Environmental Testing, Inc. certifies that the analytical results contained herein apply only to the specific samples analyzed.

Reproduction of this analytical report is permitted only in its entirety.

Ron Bennett

Project Representative

NET ®   NATIONAL ENVIRONMENTAL TESTING, INC.   JUL 1 3 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250

Tel: (317) 842-4261
Fax: (317) 842-4286

ANALYTICAL REPORT

Mr. Richard Tyler
MILBANK MANUFACTORING INC
1400 E. HAVENS ST.
KOKOMO, IN 56901-3188

07/02/1998

Job No.: 98.04205
Page 2 of 3

Date Received: 06/23/1998
Job Description: TWICE WEEKLY WASTEWATER

Sample Number / Sample I.D. Parameters	Result	Flag	Sample Date/ Units	Analyst & Date Analyzed	Method	Reporting Limit
210906 OUTFALL 001			06/23/1998			
Iron, ICP	0.86		mg/L	tjg / 07/01/1998	EPA 200.7	<0.10
Lead, ICP	<0.080		mg/L	tjg / 07/01/1998	EPA 200.7	<0.080
Silver, ICP	<0.020		mg/L	tjg / 07/01/1998	EPA 200.7	<0.020
Zinc, ICP	2.3		mg/L	tjg / 07/01/1998	EPA 200.7	<0.020

NET NATIONAL ENVIRONMENTAL TESTING, INC. ®

JUL 1 3 1998

Indianapolis Division
6964 Hillsdale Ct.
Indianapolis, IN 46250

Tel: (317) 842-4261
Fax: (317) 842-4286

FIELD REPORT

JOB #: 98.04205
CLIENT: MILBANK MFG.
PROJECT: TWICE WEEKLY WASTEWATER
DATE: 6/23/98
SAMPLER(S): NTH

An ISCO model 2910 auto sampler was used in the composite mode of operation. The sampler was equipped with a plastic composite jug, tygon suction line, battery, ice, and strainer.

All reusable equipment is decontaminated with alconox, tap water, 5% nitric acid, and deionized water. New tygon suction tubing was used for the sampler. A stainless steel strainer was also used for the sampling event.

The sampler was set to take a sample every 30 minutes for 24 hours.

Monitoring start   8:00 on 6/22/98
Monitoring end   8:00 on 6/23/98

The composite sample was cloudy, light brown color.

Notes: Samples were preserved, in the field, in the appropriate containers with any required preservative.

NATIONAL ENVIRONMENTAL TESTING, INC.

CHAIN OF CUSTODY RECORD

COMPANY _Milbank M... facturing_

ADDRESS _____

PHONE _____ FAX _____

PROJECT NAME/LOCATION _2 times weekly_

PROJECT NUMBER _____

PROJECT MANAGER _____

REPORT TO: _____

INVOICE TO: _____

P.O. NO. _____

NET QUOTE NO. _98,0060_

ANALYSES

To assist us in selecting the proper method

Is this work being conducted for regulatory compliance monitoring? Yes ____ No ____

Is this work being conducted for regulatory enforcement action? Yes ____ No ____

Which regulations apply: RCRA ____ NPDES Wastewater ____ UST ____ Drinking Water ____ Other ____ None ____

SAMPLED BY

N. Todd Hinkle (PRINT NAME)

N. Todd Hinkle (SIGNATURE)

(PRINT NAME)

(SIGNATURE)

DATE	TIME	SAMPLE ID/DESCRIPTION	MATRIX	GRAB	COMP	HCl	NaOH	HNO₃	H₂SO₄	OTHER	Metals Fe, Pb, Zn	Field Report					COMMENTS
4/23/23		2 times Weekly	W	X				1		X							liquid is milky colored.

CONDITION OF SAMPLE: BOTTLES INTACT? YES / NO   COC SEALS PRESENT AND INTACT? YES / NO   TEMPERATURE UPON RECEIPT: _3.8°C_

FIELD FILTERED? YES / NO   VOLATILES FREE OF HEADSPACE? YES / NO   Bottles supplied by NET? YES / NO

SAMPLE REMAINDER DISPOSAL: RETURN SAMPLE REMAINDER TO CLIENT VIA _____

I REQUEST NET TO DISPOSE OF ALL SAMPLE REMAINDERS _____ DATE _____

RELINQUISHED BY:	DATE	TIME	RECEIVED BY:	RELINQUISHED BY:	DATE	TIME	RECEIVED FOR NET BY:
N. Todd Hinkle	4/23/98	2:50			4/23/98	1450	C Walsh

METHOD OF SHIPMENT

REMARKS: